


NOTES:

1. Contractor shall sawcut existing pavement straight and true prior to concrete apron installation.
2. Contractor shall contact the Department of Public Works prior to concrete installation to confirm compliance.
3. Special conditions may warrant exceptions to this detail. Subject to approval by Town Engineering or Public Works Director.
4. If the street pavement section is damaged during construction activity, the contractor shall patch the pavement section to the same pavement cross section that existed prior to the commencement of construction.
5. Driveway aprons shall be constructed of a min. 4" thick, 3000 psi concrete or 6" ABC base course with a 2" asphalt surface course.



TOWN OF NAGS HEAD
 DEPARTMENT OF ADMINISTRATION
 P.O. BOX 99
 NAGS HEAD, NC 27959
 252.441.1122 • www.nagsheadnc.gov

**TYPICAL RESIDENTIAL DRIVEWAY
 CONCRETE THICKENED EDGE DETAIL**
 (THIS SECTION APPLIES TO CONCRETE DRIVEWAY INSTALLATIONS ONLY)

SCALE: NONE
 ISSUE DATE: 7-9-2015
 REVISION DATE: 1-3-2019
 SHEET NO: 1 OF 1
 DRAWN BY: DMR

DETAIL NO.:
101
 6